



In-service safety inspection and testing of electrical equipment - developed from AS3760:2003.
To be used in conjunction with 11.7. *New. Electrical Inspection & Testing.*

Workshops <ul style="list-style-type: none"> Commercial Cleaning Equipment Industrial Type Workshops. Excluding: <ul style="list-style-type: none"> Electronic Workshops Computer Workshops Performance Workshops 	Performance Theatres and Performance Workspaces*	Laboratories <ul style="list-style-type: none"> Wet/Industrial Type Laboratories Animal houses Commercial Kitchens 	All Other Areas Including: <ul style="list-style-type: none"> Electronic Workshops Computer Workshops Computer Laboratories
3 monthly All single and poly phase electrical equipment Hired or Loaned to other users	3 monthly All single and poly phase electrical equipment Hired or Loaned to other users	3 monthly All single and poly phase electrical equipment Hired or Loaned to other users	3 monthly All single and poly phase electrical equipment Hired or Loaned to other users
6 monthly All other single and poly phase electrical equipment	6 monthly <ul style="list-style-type: none"> Electrical extension leads Power boards 	12 monthly All other single and poly phase electrical equipment	12 monthly All other portable single & poly phase electrical equipment. Equipment is not portable if: <ul style="list-style-type: none"> desktop computer, monitor, fax, photocopier, microwave, fridge or freezer. length is more than 50cm in two or more dimensions and has no carry handle/s mass is greater than 18kg and has no carry handle/s Mechanically fixed or secured to the floor, wall, ceiling, structure, support or building
	12 monthly All other single and poly phase electrical equipment including: <ul style="list-style-type: none"> House lanterns Other electrical equipment. 		5 Yearly Non-portable single & poly phase electrical equipment where the socket or lead or GPO are located within 2m of ground level. Including: <ul style="list-style-type: none"> desktop computer, monitor, fax, photocopier, microwave, fridge or freezer. length is more than 50cm in two or more dimensions and has no carry handle/s mass is greater than 18kg and has no carry handle/s Mechanically fixed or secured to the floor, wall, ceiling, structure, support or building

* Additional classification added following consultation with Faculty of Victorian College of the Arts Health & Safety Representatives in June 2008.