

Schedule for in-service safety inspection and testing of electrical equipment – adapted from AS 3760 (Table 4). To be used in conjunction with the [Health & Safety: Electrical inspection and testing requirements](#). This guide is not applicable to the construction/building industry or medical equipment as defined in AS 3551.

Workshops <ul style="list-style-type: none"> Commercial Cleaning Equipment Industrial Type Workshops. Excluding: <ul style="list-style-type: none"> Electronic Workshops Computer Workshops Performance Workshops 	Performance Theatres and Performance Workspaces*	Laboratories <ul style="list-style-type: none"> Wet/Industrial Type Laboratories Animal houses Commercial Kitchens 	Other Areas <ul style="list-style-type: none"> Electronic Workshops Computer Workshops Computer Laboratories
3 monthly All single and poly phase electrical equipment hired or loaned to other users	3 monthly All single and poly phase electrical equipment hired or loaned to other users	3 monthly All single and poly phase electrical equipment hired or loaned to other users	3 monthly All single and poly phase electrical equipment hired or loaned to other users
6 monthly All other single and poly phase electrical equipment	6 monthly <ul style="list-style-type: none"> Electrical extension leads Power boards 	12 monthly All other single and poly phase electrical equipment	12 monthly All other portable single & poly phase electrical equipment. Equipment is not portable if: <ul style="list-style-type: none"> desktop computer, monitor, fax, photocopier, microwave, fridge or freezer. length is more than 50 cm in two or more dimensions and has no carry handle/s mass is greater than 18 kg and has no carry handle/s Mechanically fixed or secured to the floor, wall, ceiling, structure, support or building
	12 monthly All other single and poly phase electrical equipment including: <ul style="list-style-type: none"> House lanterns Other electrical equipment 		5 Yearly Non-portable single & poly phase electrical equipment where the socket or lead or GPO are located within 2m of ground level. Including: <ul style="list-style-type: none"> desktop computer, monitor, fax, photocopier, microwave, fridge or freezer. length is more than 50 cm in two or more dimensions and has no carry handle/s mass is greater than 18 kg and has no carry handle/s Mechanically fixed or secured to the floor, wall, ceiling, structure, support or building